

FIRE SPRINKLER SYSTEMS PLAN REVIEW *Checklist*



3609 Market Place W, Suite 200
University Place, WA 98466-4488
PH: 253.566.5656

The following are the minimum requirements needed for submittal of fire sprinkler systems to be reviewed for approval. Additional information such as clean drawings and sectional building views will greatly increase the turn-around time.

- ☐ 1. One set of 1/4" or 1/8" scale shop drawings and any other information required below.
- ☐ 2. Plan shall have a detailed scope of work.
- ☐ 3. Describe the project such as new, tenant improvement, or remodel.
- ☐ 4. Provide a site drawing showing streets, building envelope, and point of compass.
- ☐ 5. Provide one (1) set of manufacturer's product information sheets for all pipe, valves, heads, bracing integrated with the system.
- ☐ 6. Provide one (1) set of seismic calculation design sheets.
- ☐ 7. Provide one (1) set of hydraulic calculations.
- ☐ 8. Provide one (1) set of fire sprinkler riser diagram.

For questions please call the Fire Code Official at 253.460.5439.

Please note: Fire inspections are performed on Tuesdays and Wednesdays, or by prearranged appointment with Fire Code Official. Call 253.460.2540 to schedule an inspection.